

LOCATION RESTRICTION DEMONSTRATION
PLACEMENT ABOVE UPPER MOST AQUIFER
40 CFR PART 257.60
PLANT MCINTOSH ASH POND 1 (AP-1)
GEORGIA POWER COMPANY

In accordance with 40 CFR 257.60, the existing Ash Pond 1 (AP-1) is required to comply with the location restrictions related to placement above the upper most aquifer.

Based on review of site location, construction information, geology, and hydrogeology, the existing AP-1 does not meet the location requirements for being located no less than five feet above the upper most aquifer. Georgia Power expects to begin closure of AP-1 in 2019. AP-1 will be closed by removal of the coal combustion residuals (CCR) from the unit in accordance with 40 CFR 257.102.

This location restriction demonstration for the existing AP-1 was prepared under my direct supervision, direction, and control, in accordance with the Rules of Professional Conduct Chapter 180-6; and that, to the best of my knowledge, all information contained in this document is correct.



John Mathew Trast, P.E.
Registered Professional Engineer No. PE041928
Senior Consultant
GEI Consultants, Inc.

