257.83 (b) (2)	REPORT OF ANNUAL INSPECTION C	OF CCR S	URFACE IM	РО	UNDMENT	
	FACILITY NAME: Plant Wansley Ash Pond					
	OWNER/OPERATOR OF FACILITY: Georgia Power Company INSPECTION DATE: August 17, 2015 INSPECTING ENGINEER: Todd L. Barber, PE (GA Reg. # PE025787)					
	Based on the results of my inspection and review of the data provided, it is my professional					
	opinion that the report has been completed in accordance with 40 CFR 257.83(b).					
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION?				N/A*	
	(IF YES, DESCRIBE):					
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMEN	TATION				
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION			N/A*		
	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION					
	MIN. DEPTH: N/A*	MAX. DE	MAX. DEPTH: N/A*		PRESENT DEPTH: Up to 65'	
	MIN. ELEVATION: N/A*	MAX. ELEVATION:		-	PRESENT.	
		N/A*			ELEVATION: 795.6'	
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.					
	MIN. DEPTH: N/A*	MAX. DEPTH: N/A*		- 1	PRESENT DEPTH: Up to 98'	
	MIN. ELEVATION: N/A*	MAX. ELEVATION:		- 1	PRESENT	
(:)	A DDD OVINAATE CTODA CE CA DA CITY OF INADOLII	N/A*		ELEVATION: 796.6		
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUI STRUCTURE AT TIME OF INSPECTION (yd³)	2		4,603,333**		
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATE				CCR:	
	CCR AT TIME OF INSPECTION (yd³)		10,487,320*	*	14,116,013**	
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL					
	WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING					
	CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO				NO	
	DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES?					
	(IF YES, DESCRIBE):					
	(II TES, DESCRIBE).					
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION?				N/A*	
	(IF YES, DESCRIBE):					
					/AB	

^{*} This is the first 'Annual inspection by a qualified professional engineer' performed in accordance with 40 CFR Part 257.83. This information will be included in subsequent annual inspection reports.

^{**} Cubic yard estimates derived by qualified personnel from available information.

