

257.83 (b) (2)	REPORT OF ANNUAL INSPECTION OF CCR SURFACE IMPOUNDMENT		
	FACILITY NAME: Plant Yates AP-A		
	OWNER/OPERATOR OF FACILITY: Georgia Power Company		
	INSPECTION DATE: March 7, 2018		
	INSPECTING ENGINEER: Patrick B. Rhodes, P.E. (Georgia P.E. License # 24586) Southern Company Services Fossil Dam Safety		
	Based on the results of the inspection and review of the data provided by a qualified Professional Engineer, it is my professional opinion that the report has been completed in accordance with 40 CFR 257.83(b).		
(i)	ANY CHANGES IN GEOMETRY OF THE IMPOUNDING STRUCTURE SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?		YES
	(IF YES, DESCRIBE): Impoundment modified so it no longer impounds water		
(ii)	LOCATION AND TYPE OF EXISTING INSTRUMENTATION		N/A (no instrumentation)
(ii)	MAXIMUM RECORDED READING OF EACH INSTRUMENT SINCE PREVIOUS ANNUAL INSPECTION		N/A (no instrumentation)
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF THE IMPOUNDED WATER SINCE PREVIOUS ANNUAL INSPECTION		
	MIN. DEPTH: 0-ft	MAX. DEPTH: 0-ft	PRESENT DEPTH: 0-ft
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT ELEVATION: N/A
(iii)	APPROXIMATE MINIMUM, MAXIMUM AND PRESENT DEPTH AND ELEVATION OF CCR SINCE PREVIOUS ANNUAL INSPECTION.		
	MIN. DEPTH: 0-ft	MAX. DEPTH: 0-ft	PRESENT DEPTH: 0-ft
	MIN. ELEVATION: N/A	MAX. ELEVATION: N/A	PRESENT ELEVATION: N/A
(iv)	APPROXIMATE STORAGE CAPACITY OF IMPOUNDING STRUCTURE AT TIME OF INSPECTION.	0 cu yds*	
(v)	APPROXIMATE VOLUME OF IMPOUNDED WATER AND CCR AT TIME OF INSPECTION	WATER: 0 cu yds *	CCR: 0 cu yds *
(vi)	ANY APPEARANCE OF AN ACTUAL OR POTENTIAL STRUCTURAL WEAKNESS OF THE CCR UNIT, IN ADDITION TO ANY EXISTING CONDITIONS THAT ARE DISRUPTING OR HAVE THE POTENTIAL TO DISRUPT THE OPERATION AND SAFETY OF THE CCR UNIT AND APPURTENANT STRUCTURES (YES OR NO)?		N/A*
	(IF YES, DESCRIBE): N/A		
(vii)	ANY OTHER CHANGE(S) WHICH MAY HAVE AFFECTED THE STABILITY OR OPERATION SINCE THE PREVIOUS ANNUAL INSPECTION (YES OR NO)?		N/A*
	(IF YES, DESCRIBE): N/A		

* Yates AP-A has had all ash removed and no longer has the ability to impound water. Plant Yates no longer burns coal, thus no longer generates CCR nor stores CCR in this area

