

**LOCATION RESTRICTION DEMONSTRATION
WETLANDS (40 C.F.R. PART 257.61)
PLANT YATES ASH POND A (AP-A)
GEORGIA POWER COMPANY**

Plant Yates AP-A is subject to the timelines announced in 81 Fed. Reg. 51802 (Aug. 5, 2016). EPA's "Disposal of Coal Combustion Residuals from Electric Utilities Final Rule" (40 C.F.R. Part 257.61) requires that a CCR Surface Impoundment must not be located within wetlands, as defined by the U.S. Army Corps of Engineers, without special considerations and permitting.

Based on a review of the National Wetlands Inventory map, there are no jurisdictional wetlands identified within the limits of AP-A. Therefore, AP-A meets the Proximity to Wetlands restriction § 257.61.

I hereby certify that for Georgia Power's Plant Yates AP-A, the wetlands location restriction demonstration meets the requirements of 40 C.F.R. § 257.61(a).



Richard T Deason, P.E.
Atlantic Coast Consulting, Inc.

SEAL

