

# Clearances For Swimming Pools

NOTES:

1. Direct buried cables shall not be installed within five feet of a swimming pool or its auxiliary equipment.
2. If five feet can not be maintained supplemental mechanical protection shall be provided.

